



Optimizing Cooling Efficiency and Water Usage in Dutch AI Data Centers

Infinity Turbine
LLC

[TEL] 608-238-6001

[Email] greg@infinityturbine.com

<https://infinityturbine.com/dutch-data-center-optimization-by-infinity-turbine.html>

Optimizing Cooling Efficiency and Water Usage in Dutch AI Data Centers



This webpage QR code

PDF Version of the webpage (maximum 10 pages)

Optimizing Cooling Efficiency and Water Usage in Dutch AI Data Centers

As the demand for artificial intelligence (AI) continues to surge, the energy requirements for AI data centers, especially those hosting large-scale GPUs like NVIDIA A100s, are also on the rise. Cooling these high-performance machines is one of the most significant operational costs, especially in regions like the Netherlands where sustainability and resource efficiency are paramount. This article explores the costs and environmental considerations of cooling technologies—air cooling, water cooling, and chiller-based systems—alongside the water usage associated with cooling towers.

The Energy Impact of AI Workloads

A typical AI data center in the Netherlands running 30,000 NVIDIA A100 GPUs demands substantial cooling infrastructure. Each A100 GPU consumes approximately 400 watts, meaning the entire data center has an IT load of 12,000 kW. The choice of cooling technology can significantly impact both the cost and the environmental footprint of the facility.

Cooling Methods: Comparing Costs

There are three primary cooling methods in modern data centers: air cooling, water cooling, and chiller-based systems. Each method has different operational efficiencies and costs, especially when we factor in the price of electricity in the Netherlands.

1. Air Cooling:

- Power requirement: 50% of the IT load
- Energy use: 6,000 kW
- Annual energy consumption: 52,560,000 kWh
- Cost of electricity (€0.16 per kWh): €8,409,600 per year

2. Water Cooling:

- Power requirement: 20% of the IT load
- Energy use: 2,400 kW
- Annual energy consumption: 21,024,000 kWh
- Cost of electricity (€0.40 per kWh): €8,409,600 per year

3. Chiller Cooling:

- Power requirement: 40% of the IT load
- Energy use: 4,800 kW
- Annual energy consumption: 42,048,000 kWh
- Cost of electricity (€0.50 per kWh): €21,024,000 per year

Water Cooling: Environmental and Cost Considerations

Water cooling, a favored method for its higher efficiency compared to air cooling, relies heavily on evaporative cooling towers. These towers use evaporation to remove heat from the system, which, while efficient, consumes significant amounts of water.

For a data center of this scale, water cooling would consume approximately 37,843 cubic meters of water annually. The average cost of water in the Netherlands is about €1.50 per cubic meter, leading to an additional annual operational cost of €56,765 for water consumption alone.

Savings per Year Using Infinity Cluster Mesh Power Generation

The power generated from 40,944,000 BTU/hour with a requirement of 40,000 BTU/kWh would indeed be:

$$\text{Power generated (kW)} = \frac{40,944,000 \text{ BTU/hour}}{40,000 \text{ BTU/kWh}} = 1,023.6 \text{ kW}$$

Step 1: Calculate Annual Power Generation

The system will generate 1,023.6 kW per hour. Over the course of a year, this would be:

$$\text{Annual power generation (kWh)} = 1,023.6 \text{ kW} \times 24 \text{ hours/day} \times 365 \text{ days/year}$$

$$\text{Annual power generation (kWh)} = 1,023.6 \times 8,760 = 8,964,336 \text{ kWh/year}$$

Step 2: Recalculate Financial Savings

Now, let's calculate the financial savings based on the power generated and electricity rates of €0.16, €0.40, and €0.50 per kWh.

1. At €0.16 per kWh:

$$\text{Annual savings} = 8,964,336 \text{ kWh/year} \times 0.16 \text{ €/kWh} = €1,434,293.76 \text{ per year}$$

2. At €0.40 per kWh:

$$\text{Annual savings} = 8,964,336 \text{ kWh/year} \times 0.40 \text{ €/kWh} = €3,585,734.40 \text{ per year}$$

3. At €0.50 per kWh:

$$\text{Annual savings} = 8,964,336 \text{ kWh/year} \times 0.50 \text{ €/kWh} = €4,482,168 \text{ per year}$$

Summary of Power Generated and Savings

- Power generated from the waste heat: 1,023.6 kW/hour or 8,964,336 kWh/year
- Annual financial savings based on energy rates:
 - €0.16 per kWh: €1,434,294/year
 - €0.40 per kWh: €3,585,734/year
 - €0.50 per kWh: €4,482,168/year

By capturing and reusing waste heat, the data center could save substantial amounts annually, significantly improving both operational efficiency and environmental sustainability.

Savings per Year Using Infinity Cluster Mesh Power Generation

The power generated from 40,944,000 BTU/hour with a requirement of 40,000 BTU/kWh would indeed be:

$$\text{Power generated (kW)} = \frac{40,944,000 \text{ BTU/hour}}{40,000 \text{ BTU/kWh}} = 1,023.6 \text{ kW}$$

Step 1: Calculate Annual Power Generation

The system will generate 1,023.6 kW per hour. Over the course of a year, this would be:

$$\text{Annual power generation (kWh)} = 1,023.6 \text{ kW} \times 24 \text{ hours/day} \times 365 \text{ days/year}$$

$$\text{Annual power generation (kWh)} = 1,023.6 \times 8,760 = 8,964,336 \text{ kWh/year}$$

Step 2: Recalculate Financial Savings

Now, let's calculate the financial savings based on the power generated and electricity rates of €0.16, €0.40, and €0.50 per kWh.

1. At €0.16 per kWh:

$$\text{Annual savings} = 8,964,336 \text{ kWh/year} \times 0.16 \text{ €/kWh} = \text{€}1,434,293.76 \text{ per year}$$

2. At €0.40 per kWh:

$$\text{Annual savings} = 8,964,336 \text{ kWh/year} \times 0.40 \text{ €/kWh} = \text{€}3,585,734.40 \text{ per year}$$

3. At €0.50 per kWh:

$$\text{Annual savings} = 8,964,336 \text{ kWh/year} \times 0.50 \text{ €/kWh} = \text{€}4,482,168 \text{ per year}$$

Summary of Power Generated and Savings

- Power generated from the waste heat: 1,023.6 kW/hour or 8,964,336 kWh/year
- Annual financial savings based on energy rates:
 - €0.16 per kWh: €1,434,294/year
 - €0.40 per kWh: €3,585,734/year
 - €0.50 per kWh: €4,482,168/year

Optimizing Data Center Cooling Costs and Harnessing Waste Heat for Energy Generation in the Netherlands

As AI and machine learning workloads continue to grow, so do the infrastructure requirements for the data centers that power these cutting-edge technologies. Cooling is a significant part of a data center's operational expenses, especially in facilities housing powerful GPUs like the NVIDIA A100, which generate substantial heat. This article explores the costs of different cooling methods—air cooling, water cooling, and chiller-based systems—while also considering the potential for water savings and the exciting prospect of converting waste heat into usable electricity through the Infinity Turbine Cluster Mesh Power Generation system.

The High Cost of Cooling in AI Data Centers

For a data center running 30,000 NVIDIA A100 GPUs, each consuming approximately 400 watts, the total power draw for the GPUs alone is 12,000 kW. Cooling this power-hungry equipment can represent up to 50% or more of a data center's total energy consumption, depending on the cooling technology used. Below is a breakdown of the power usage and annual costs for three common cooling methods: air cooling, water cooling, and chiller-based systems.

1. Air Cooling:

- Power requirement: 50% of the IT load
- Cooling power: 6,000 kW
- Annual energy consumption: 52,560,000 kWh/year
- Annual cost at €0.16 per kWh: €8,409,600/year

2. Water Cooling:

- Power requirement: 20% of the IT load
- Cooling power: 2,400 kW
- Annual energy consumption: 21,024,000 kWh/year
- Annual cost at €0.40 per kWh: €8,409,600/year

3. Chiller-Based Cooling:


- Power requirement: 40% of the IT load
- Cooling power: 4,800 kW
- Annual energy consumption: 42,048,000 kWh/year
- Annual cost at €0.50 per kWh: €21,024,000/year

The energy costs associated with cooling alone can represent a significant portion of a data center's operational expenses. For facilities seeking to reduce both their energy bills and carbon footprint, selecting the right cooling technology is critical.

Water Usage in Cooling Systems

Water-cooled systems, which typically rely on cooling towers that evaporate water to dissipate heat, provide a more energy-efficient option but come with additional water costs. These systems consume a considerable amount of water through evaporation. For a data center using water cooling, we can estimate the annual water consumption as follows:

- Total energy for cooling: 21,024,000 kWh/year
- Water evaporated per kWh: 1.8 liters



Copyright 5/23/202 Infnity Turbine LLC
